

ADDENDUM NO. 1

DATE: August 15, 2017

Project: Hudson Area Public Library District
Re-Roofing

Architect: StudioGC architecture + interiors
223 W. Jackson Blvd. Suite 1200
Chicago, Illinois 60606

Project No.: 17034

1.1 SUMMARY

- A. The Bidding Documents and Project Manual dated August 14, 2017 and Drawings dated August 14, 2017 for the above referenced project are hereby modified and revised as follows.
- B. The information contained within this Addendum modifies, supplements or replaces information contained in the Project Manual and the Contract Drawings and is hereby made a part of the Contract Documents.
- C. Acknowledge receipt of this Addendum on the Bid Form. FAILURE TO DO SO MAY SUBJECT THE BIDDER TO DISQUALIFICATION.
- D. The Bidding Documents include the Project Manual dated August 14, 2017, the Drawings dated August 14, 2017, and Addenda issued prior to the receipt of bids.

1.2 PROJECT MANUAL

- A. None

1.3 DRAWINGS

- A. **Sheet AD3.00; Revise the following note in all locations:**
 - 1. Detail 1, Detail 3
 - a. EXISTING 4'-0" SELF ADHERING ROOF UNDERLAYMENT STRIP ALONG ROOF EDGES IS TO REMAIN.
- B. **Sheet A3.00; Add the following note:**
 - 1. NOTE: PRIOR TO ORDERING THE ROOF UNDERLAYMENT, THE CONTRACTOR SHALL REMOVE A 4' x 4' (OR SMALLER) AREA OF THE ROOF TO DETERMINE THE TYPE OF EXISTING SELF ADHERING ROOF UNDERLAYMENT. THE NEW UNDERLAYMENT SHALL BE COMPATIBLE WITH THE EXISTING TYPE. THE ROOF SHALL BE PATCHED TEMPORARILY UNTIL THE WORK CAN COMMENCE.

1.4 CLARIFICATIONS

- A. None

End Addendum 009113.1
This Addendum consists of 1 pages.
Attachments: None